



Shenzhen Bontek Compliance Testing Laboratory Co., Ltd.

CE Certificate of Conformity

Certification number: BCT13HC-1498E

Report number: BCT13HR-1498E

Shenzhen Bontek Compliance Testing Laboratory Co., Ltd. hereby declares that testing has been completed and reports have been generated for:

Applicant: **NORTEC SA DE CV**
Address: Miguel Aleman B7, Col. Jardines de la Victoria, 67119 Guadalupe, Nuevo Leon, Mexico
Manufacturer: **NORTEC SA DE CV**
Address: Miguel Aleman B7, Col. Jardines de la Victoria, 67119 Guadalupe, Nuevo Leon, Mexico
Product: **UNINTERRUPTIBLE POWER SUPPLY**
Model: **UPS-IND 1110, UPS-IND 1118, UPS-IND 1122, UPS-IND 1122 Rack, UPS-IND 1222**
Trade Mark: **INDUSTRONIC**

And, in accordance with the following applicable directives:

2004/108/EC Electromagnetic Compatibility (As Amended)

That this product has been assessed against the following applicable standards;

EMC
EN 62040-2:2006
EN 61000-3-11:2000
EN 61000-3-12:2011

Therefore, Shenzhen Bontek Compliance Testing Laboratory Co., Ltd hereby acknowledges that the applicant may issue a DECLARATION of CONFORMITY and apply the CE marking in accordance with European Union Rules

Attestation by

Kendy Wang



Date of Issued: August 21, 2013

1/F, Block East H-3, OCT Eastern Ind. Zone, Qiaocheng East Road, Nanshan, Shenzhen, P.R. China
Tel: 86-755-86337020 Fax: 86-755-86337028 <http://www.bontek.com.cn>

Attachment File For The BCT13HC-1498E

Model List

Model name	Input	Output
UPS-IND 1110	AC 120V, 60Hz, 8A DC 36V, 26A	AC 120V, 60Hz, 8.3A,1000VA, 800W
UPS-IND 1118	AC 120V, 60Hz, 15.6A DC 72V, 25.5A	AC 120V, 60Hz, 16.5A,2000VA, 1600W
UPS-IND 1122	AC 120V, 60Hz, 23.3A DC 96V, 29.1A	AC 120V, 60Hz, 25A,3000VA, 2400W
UPS-IND 1122 Rack	AC 120V, 60Hz, 21.5A DC 96V, 26A	AC 120V, 60Hz, 25.6A,3000VA, 2100W
UPS-IND 1222	AC 220V, 60Hz, 15A DC 96V, 30A	AC 120V, 60Hz, 8.3A,3000VA, 2100W

