



Shenzhen Bontek Compliance Testing Laboratory Co., Ltd.

CE Certificate of Conformity

Certification number: BCT13HC-1498S

Report number: BCT13HR-1498S

Shenzhen Bontek Compliance Testing Laboratory Co., Ltd. hereby declares that testing has been completed and reports have been generated for:

Applicant: NORTEC SA DE CV
Address: Miguel Aleman B7, Col. Jardines de la Victoria, 67119 Guadalupe, Nuevo Leon, Mexico

Manufacturer: NORTEC SA DE CV
Address: Miguel Aleman B7, Col. Jardines de la Victoria, 67119 Guadalupe, Nuevo Leon, Mexico

Product: UNINTERRUPTIBLE POWER SUPPLY
Model: UPS-IND 1110, UPS-IND 1118, UPS-IND 1122, UPS-IND 1122 Rack, UPS-IND 1222

And, in accordance with the following applicable directives:

2006/95/EC Low Voltage Directive

That this product has been assessed against the following applicable standards;

LVD

EN 62040-1:2008

Uninterruptible power systems (UPS) - Part 1: General and safety requirements for UPS

Therefore, Shenzhen Bontek Compliance Testing Laboratory Co., Ltd hereby acknowledges that the applicant may issue a DECLARATION of CONFORMITY and apply the CE marking in accordance with European Union Rules.

Attestation by:



Kendy Wang

Date of Issued: August 21, 2013

1/F, Block East H-3, OCT Eastern Ind. Zone, Qiaocheng East Road, Nanshan, Shenzhen, China

Tel: +86-755-86337020 Fax: +86-755-86337028 <http://www.bontek.com.cn>



Attachment File For The BCT13HC-1498S

Model List

| Model name | Input | Output |
|----------------------|---------------------------------------|---------------------------------------|
| UPS-IND 1110 | AC 120V, 60Hz, 8A DC 36V, 26A | AC 120V, 60Hz, 8.3A,1000VA, 800W |
| UPS-IND 1118 | AC 120V, 60Hz, 15.6A DC 72V, 25.5A | AC 120V, 60Hz, 16.5A,2000VA, 1600W |
| UPS-IND 1122 | AC 120V, 60Hz, 23.3A DC 96V, 29.1A | AC 120V, 60Hz, 25A,3000VA, 2400W |
| UPS-IND 1122 Rack | AC 120V, 60Hz, 21.5A DC 96V, 26A | AC 120V, 60Hz, 25.6A,3000VA, 2100W |
| UPS-IND 1222 | AC 220V, 60Hz, 15A DC 96V, 30A | AC 120V, 60Hz, 8.3A,3000VA, 2100W |

