

C E R T I F I C A T E

Of Conformity
EC Council Directive 2004/108/EC
Electromagnetic Compatibility

Registration No.: AT1404678E

Report No.: 201404738E

Page 1 of 2

Applicant : NORTEC SA DE CV
Miguel Aleman B7, Col. Jardines De La Victoria, 67119
Guadalupe, Nuevo Leon, Mexico

Product : UNINTERRUPTIBLE POWER SUPPLY


Identification : **Model No.** : UPS-IND 13120, UPS-IND 13160,
UPS-IND 13200, UPS-IND 13250,
UPS-IND 13300, UPS-IND 13400

Trade Mark : INDUSTRONIC

Rating : see page 2 for details

Test Standards : EN 62040-2: 2006
EN 61000-3-2: 2006+A1: 2009+A2: 2009
EN 61000-3-3: 2013

The certificate of conformity is based on an evaluation of a sample of the above-mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex III of Council Directive 2004/108/EC, in its latest amended version, referred to EMC Directive. The certificate does not imply assessment of the production and does not permit the use of Lab's logo. The applicant of the certificate is authorized to use this certificate in connection with EC declaration of conformity to Article 10.1 of the Directive.



Certified by

Tom Chen
Tom Chen
Manager

Apr. 11, 2014
Date



The CE Marking may only be used if all relevant and effective EC Directives are complied with



Shenzhen Anbotek Compliance Laboratory Limited

1/F., Building 1, SEC Industrial Park, No.0409 Qianhai Road,
Nanshan District, Shenzhen, Guangdong, China
[Http://www.anbotek.com](http://www.anbotek.com)

Tel:(86)755-26066544
Fax: (86)755-26014772
Email: service@anbotek.com


C E R T I F I C A T E

CERTIFICATE Of Conformity EC Council Directive 2004/108/EC Electromagnetic Compatibility

Registration No.: AT1404678E

Report No.: 201404738E
Page 2 of 2

Model:	Rating:
UPS-IND 13120	Input: 3W+N+PE, 200-220VAC, 50/60Hz, 462A Output: 3W+N+PE, 200/ 208/ 220VAC, 50/60Hz, 120kVA/96KW, 348VDC, 296A
UPS-IND 13160	Input: 3W+N+PE, 200-220VAC, 50/60Hz, 616A Output: 3W+N+PE, 200/ 208/ 220VAC, 50/60Hz, 160kVA/128KW, 348VDC, 394A
UPS-IND 13200	Input: 3W+N+PE, 200-220VAC, 50/60Hz, 801A Output: 3W+N+PE, 200/ 208/ 220VAC, 50/60Hz, 200kVA/160KW, 348VDC, 491A
UPS-IND 13250	Input: 3W+N+PE, 200-220VAC, 50/60Hz, 971A Output: 3W+N+PE, 200/ 208/ 220VAC, 50/60Hz, 250kVA/200KW, 348VDC, 614A
UPS-IND 13300	Input: 3W+N+PE, 200-220VAC, 50/60Hz, 1172A Output: 3W+N+PE, 200/ 208/ 220VAC, 50/60Hz, 300kVA/240KW, 348VDC, 736A
UPS-IND 13400	Input: 3W+N+PE, 200-220VAC, 50/60Hz, 1572A Output: 3W+N+PE, 200/ 208/ 220VAC, 50/60Hz, 400kVA/320KW, 348VDC, 980A



Certified by

Tom Chen
Tom Chen
Manager

Apr. 11, 2014
Date



The CE Marking may only be used if all relevant and effective EC Directives are complied with



Shenzhen Anbotek Compliance Laboratory Limited

1/F., Building 1, SEC Industrial Park, No.0409 Qianhai Road,
Nanshan District, Shenzhen, Guangdong, China
[Http://www.anbotek.com](http://www.anbotek.com)

Tel:(86)755-26066544
Fax: (86)755-26014772
Email: service@anbotek.com